

February 25, 2022

ADDENDUM NO. 2

Via Email
No. of Pages: 1

BID NO: Contract for the Athletic Complex #4
Softball Field Light Pole Repair Project
Located at 950 Langham Rd., Beaumont, Texas 77707

BID NO.: TF0122-12

Please be advised of the following updated information pertaining to the referenced RFP:

1. The following additions, deletions, modifications, or clarifications shall be made to the appropriate sections of the plans and specifications and shall become part of the contract document.
2. All bidders are herewith notified of the following additions, deletions, changes or clarifications to the original Specifications, Contract Documents and Contract Drawings.
3. **Be advised the following question has been submitted pertaining to this project and is hereby answered :**

QUESTION:

Requesting the welding procedure for the ultrasonic testing prior to pricing.

ANSWER:

All welding shall comply with the procedures in the American Welding Society AWS D1.1.

When submitting bid responses, bidders MUST acknowledge this Addendum No. 2 on page 25 of the bid specifications.

If we can be of further service, please do not hesitate to call Terry Welch at 409-880-3107 or 409-880-3720.

Sincerely,



Terry Welch
Purchasing Manager

TW:bd G:\BIDS - DO NOT MOVE OR DELETE\Pu22\Pu-F-22\TF0122-12_Add 2_BD.docx

cc: Keith Folsom, Facilities Maintenance

PURCHASING
T 409.880.3720
F 409.880.3747
PO Box 3827 | Beaumont, TX 77704
801 Main St. | Suite 315 | Beaumont, TX 77701
beaumonttexas.gov

